











Golden Fin

### ESPECIFICACIONES TÉCNICAS

Ficha Homologada: Si Tipo: Split Unitario Pared Modo de Operación: Frío Solo Tipo de Compresor: Inverter

Capacidad Comercial (BTU/H): 18,000 BTU/H

Capacidad de Enfriamiento Máxima (BTU/H): 20,125 BTU Gas Refrigerante: R410A

Factor de Eficiencia: SEER (A)(>=5,60); 6,4 W/W

Tensión de Funcionamiento: 220V

Frecuencia: 60HZ

Garantía de Fábrica en Partes: 3 años on site

Unidad de Despacho: POR UNIDAD

Marca: MIDEA

Modelo del Condensador: MOX230-17CFN1-MT0W

Nro Parte: MOX230-17CFN1-MT0W

Modelo del Evaporador: MSAG11C-17CRFN1-MT0W Evaporador: MSAG11C-17CRFN1-MT0W





\*Comparado con minisplit convencional en las mismas condiciones de operación en laboratorios Midea.

Los resultados pueden variar dependiendo del modelo, las condiciones de operación y del medio ambiente.



## **MINISPLIT**

# INFINI (AG)

MOX230-17CFN1-MT0W 18 000 Btu/h

Empaque de Fábrica: Caja

Componentes: 3 Mts de Tubería de cobre, Module WIFI y Control Remoto

Área a Cubrir (m2): Hasta 30 (varía según condición)

Rango de Operación: 7,000 Btu/H~20,125 Btu/H (Min~Max)

Nivel de Ruido Interior (Alta - Media - Baja): 46/38 5/31 5 dB(A)

Nivel de Ruido Exterior: 54 dB(A) Filtro de Aire: SI; Doble filtrado

Control de Temperatura: Control remoto inalámbrico

Limpieza Automática: SI

Protección Anticorrosiva: GOLD FIN

Modo ECO: SI

Enfriamiento Turbo: SI Tecnología: INVERTER

Control Inalámbrico y Por Voz: SI; Desde la APP Midea

Procedencia: China

Material Unidad Interior: Panel de Plástico Polipropileno

Material Unidad Exterior: Acero Galvanizado

Máxima Longitud de Tubería: 30 mts

Máxima Longitud en Vertical de Tubería: 20 mts



### **Unidad Interior**



Modelo	Capacidad BTU/h	Refrigerante	Voltaje	Longitud de Tubería	Longitud Máxima	
MOX230-17CFN1-MT0W	18,000 Btu/h	R410a	220 V	30 mts	25 mt	s
	Madala Unidad Interior		Madala IIni	dad Exterior		

	Modelo Unidad Interior	Modelo Unidad Exterior	
Modelo Set	Dimensiones (WxDxH) mm	Dimensiones (WxDxH) mm	
	MSAG11C-17CRFN1-MT0W	MOX230-17CFN1-MT0W	
MOX230-17CFN1-MT0W	765x303x555 cm		



# **Certificate of Product Ratings**

AHRI Certified Reference Number: 207335064 Date: 06-28-2024 Model Status: Active

AHRI Type: RCU-A-CB-O (Mini-Split Air-Conditioner, with Remote Outdoor Unit-Air-Source, Free Delivery)

Outdoor Unit Brand Name: MIDEA

Outdoor Unit Model Number: MOX230-17CFN1-MT0W

Indoor Type: Mini-Splits (Non-Ducted)

Indoor Model Number(s): MSAG11C-17CRFN1-MT0W

Region Note: On January 1, 2023, efficiency standards increased for central air conditioners. Beginning January 1, 2023, central air

conditioners can only be installed in region(s) for which they meet the new regional efficiency requirements.

Rated as follows in accordance with the latest edition of AHRI 210/240 - 2017 with Addendum 1, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (A2) - Single or High Stage (95F), btuh: 17500

SEER: 21.00

EER (A2) - Single or High Stage (95F): 11.30

Rated as follows in accordance with the latest edition of AHRI 210/240 - 2023, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (AFull) - Single or High Stage (95F), btuh: 17500

SEER2: 21.00

EER2 (AFull) - Single or High Stage (95F): 11.30

Sold in?: USA, Canada

CERTIFIED

?"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. Production Stopped? Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

The Department of Energy has published updated energy efficiency metrics for central air conditioners and heat pumps. This publication reflects both the 1987 metric (SEER) and the 2023 metric (SEER2). Efficiency requirements are published at 10 C.F.R. 430.32(c). Please refer to www.AHRInet.org for more information about updated energy efficiency metrics.

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

### **TERMS AND CONDITIONS**

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

### **CERTIFICATE VERIFICATION**

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

CERTIFICATE NO.:

133640841250416360

& REFRIGERATION INSTITUTE

we make life better™

©2024 Air-Conditioning, Heating, and Refrigeration Institute